## SUBMERSIBLE LIFT STATION

## GENERAL SPECIFICATION GUIDE

### FALL CREEK REGIONAL WASTE DISTRICT

### DUPLEX NON-CLOG SEWAGE LIFT STATION - CONCRETE WELL

- Scope of Work:
- A. Furnish all labor, equipment and material to construct one duplex Submersible pumping station consisting of pumps, motors, wet basin, separate valve pit, valves, piping, hatches, guide rails, pump removal components, control center, float switches, remote monitor, interconnecting electrical wiring, incoming power supply, and other features regularly and normally required as a part of a complete and functional facility. All work shall be in accordance with site requirements, details in the plans, these specifications and the manufacturer's recommendations.

### II. General Requirements:

- A. All of the mechanical and electrical equipment shall be an intregal package supplied by the pump manufacturer with local representation so as to provide undivided responsibility. The package shall be Hydromatic Pump equipment and USEMCO
- B. The contractor shall submit to the Project Engineer for review and approval, three (3) sets of shop drawings, detailed specifications, pump warranty and performance characteristics for all of the equipment and fixtures to be furnished and installed. The Project Engineer will review the submittal and render a decision in writing as to the acceptability of the equipment. Without prior written engineering approval, the item of work may not be accepted.
- Any exceptions to this standard or associated approved plans shall be submitted in writing and clearly stated. The exceptions must be approved by the Engineer prior to proceeding with the work
- All components of the lift station that are exposed to weather shall be constructed of material that is resistant to corrosion and will not surface protection throughout the expected life of the lift station.

### Operating Conditions:

- Each pump shall have a capacity of 321 gallons per minute at Α. a total dynamic head of 109 feet when operating The pump motor shall be a minimum 25 horsepower, 1750 RPM, 460 volt, 3 phase, 60 cycle. Each pump shall be provided with 50 feet of power cable and sensor cable. The pump shall be a pump model S4Q as manufactured by Hydromatic.
- IV. Pumping Equipment:
  - Pumps shall be of the submersible type for handling raw unscreened sewage. Pump volute, motor and seal housing are to be high quality gray cast iron. Impeller shall be either cast iron or cast bronze of a non-clog design capable of handling minimum three (3) inch sphere solids, fibrous material, heavy sludge and other matter found in normal sewage applications. Impeller shall have pump out vanes on the back shroud of the impeller to keep pumped material away from the seal area and increase operating life. Impeller shall be either slip fit or taper fit with key to securely lock the impeller to the driving shaft. The pump volute shall be fit with a replaceable bronze wear ring to minimize wear on the impeller and help achieve longer balanced operating life. All fasteners shall be of stainless steel.
  - All mating surfaces where water tight sealing is required shall be machined and fitted with nitrile rubber O-rings. Sealing shall be accomplished when metal-to-metal contact is made, resulting in controlled compression of the rubber O-rings without requirement of VI. Disconnect Switch: a specific torque limit.
- C. The pump shall be provided with a mechanical rotating shaft seal system running in an oil reservoir having separate, constantly lubricated lapped seal faces. The lower seal unit between the pump and oil chamber shall consist of one (1) stationary seat and one (1) rotating ring held in place by its own spring. The lower seal shall be removable wit hout disassembling the seal chamber. The upper seal between the motor and the seal chamber shall be of the same design with its own separate spring system. The seals shall require neither maintenance nor adjustment, but shall be easily inspected and replaceable. Shaft seals with conventional double seal utilizing a single spring between the two seals and requiring a pressure differential to offset external pressure shall not be considered acceptable nor equal to the dual independent seal system specified. The shaft sealing system shall be capable of operating submerged to pressures equivalent to two hundred (200) feet. No seal damage shall result from operating the pump unit out of its liquid environment. The seal system shall not rely upon the pumped media for lubrication. Pumps with bronze bushing between mechanical seals will not be acceptable. The seal chamber shall also be equipped with a seal failure sensor probe which will sense water intrusion through the lower seal. This sensor is to be connected to an alarm in the control panel to indicate lower seal failure.
- The stator winding, rotor and bearings are to be mounted in a D. sealed submersible type housing. Insulation utilized in the stator windings shall be class F with maximum temperature capability of 155 degrees Centigrade. Motor housing shall be filled with a highdielectric oil to give superior heat transfer and allow the bearings to run in a clean, well lubricated environment; or the housing shall be air filled with grease lubricated bearings. The pump and motor are to be specifically designed so that they may be operated partially or completely submerged in the liquid being pumped. The pump should not require cooling water jackets. Stators shall be securely held in place with a removable end ring and threaded fasteners so that it may be easily removed in the field without use of heat or a press without exception.

Shaft shall be of stainless steel and supported by ball bearings. Motor shall be provided with heat sensing units attached to the motor windings, which shall be connected to the control panel to shut down the pump if overheating occurs.

- Pump motor cable and heat sensor /seal failure sensor cable shall be suitable for submersible pump applications and this shall be indicated by a code or legend permanently embossed on the cable. Cable sizing shall conform to NEC specifications for pump motors and shall be of adequate size to allow motor voltage conversion without replacing the cable. Cable of the proper length shall be shall be provided to eliminate the need for splices or junction boxes between pump and 'Control Center'. The cable shall enter the motor through a cord cap assembly which is double-sealed allowing disassembly and disconnect of the wires at the motor and still not damage the sealed characteristics of the motor housing. Each individual conductor shall be color coded in accordance with generally accepted industry standards. The color coding shall designate the application of the conductor.
- The pump mounting base shall include adjustable guide rail supports and a discharge connection with a one hundred twenty-five (125) pound standard flange. The base and the discharge piping shall be permanently mounted in place.
- G. A rail system shall be provided for easy removal of the pump and motor assembly for inspection and service. The system shall not require a man to enter the wet well to remove the pump and motor assembly. One (1) H type fiberglass reinforced plastic (FRP) I-Beam shall be provided for each pump.

- The pumps shall be equipped with sliding brackets or rail guides. To insure easy removal of the pumps, the rail guides attached to each pump shall not encircle the rails. A stainless steel lifting chain of adequate length for the basin depth shall be provided for each pump.
- The rails and rail guides shall function to allow the complete weight of the pumping unit to be lifted on dead center without binding and stressing the pump housing. The rail system shall function to automatically align the pumping unit to the discharge connection by a simple downward movement of the pump. No twisting or angle approach will be considered acceptable. The actual sealing of the discharge interface will be of the hydraulically sealing diaphragm type assembly with removable Buna -N diaphragm as supplied by Hydromatic Pump.
- Pump warranty shall be provided by the pump manufacturer and shall warrant the units being supplied to the Owner against defects in workmanship and materials for a period of five (5) years under normal use, operation and service. The warranty shall be in printed form and apply to all similar units. A copy of the warranty statement shall be submitted with the approval drawings.

V. Basin, Valve Pit and Accessories:

- The basin and valve pit are to be constructed of precast concrete. Α. The actual arrangement of the structures is to be as shown in the approved plans. The wet well basin top shall be provided with a four (4) inch PVC vent having a downward pointing inlet and screen over the inlet opening.
- The basin, valve pit, flat tops and base slabs are to be constructed Β. of precast reinforced concrete manhole sections conforming to ASTM C-478. All joints between precast sections shall be made with an approved rubber O-ring in accordance with ASTM C-443 and a 1/2 inch diameter non-asphaltic mastic conforming to AASHTO M-198 and Federal Specification SS-521-A. In addition, the outside wall below grade is to be coated with bituminous waterproofing material. The top and bottom of the chambers shall be precast or may be poured in place concrete if approved by the Engineer.
- C. The pump supplier shall to provide an aluminum two (2) door access hatch frame and door assembly to be installed in the concrete basin top. This door assembly shall provide access for removal of the pumps and shall support the guide rails. The doors shall be provided with lifting handle, safety latch to hold door in the open position and a hasp suitable for a padlock. The doors shall have a non-skid finish, designed for light, medium or heavy duty, depending on the location of the pumping station.
- An aluminum single door access hatch frame and door assembly, D. similar to the one described above, shall be provided for use as entry to the valve pit. Minimum opening for the valve box entry shall be thirty-six (36) inches by thirty-six (36) inches.
- A swing check valve with external swing arm and an eccentric plug valve shall be installed in the valve pit in each pump's discharge piping. A minimum clearance of twelve (12) inches shall be allowed from the bottom of the valves to invert of the pit. A drain pipe and ball valve shall be installed to drain the valve pit back to the wet basin, but not allow the wet basin liquid to enter the valve pit
- A 4" PVC schedule 80 pump suction line shall be provided from within 12" of the basin floor up through the basin top casting for use as an emergency pump suction connection as shown on the plans. The suction line shall terminate 12" above the top of the casting with a 90 degree elbow and quick disconnect flange matching the Fall Creek Regional District portable pumping equipment. The 4" Camlock quick disconnect shall also be provided with an air tight cap.
- The discharge piping in the valve pit shall be provided with a 4" G. plug valve and a 4" Camlock quick disconnect fitting in the common discharge pipe, after the individual pump plug valves, for IX. use as an emergency pump discharge connection as shown on the plans. The quick disconnect fitting shall match the Fall Creek Regional Waste District portable pumping equipment.

- A single main disconnect switch of adequate size to provide power for the 'Control Center' and its related components shall be provided by the Contractor.
- The disconnect switch shall be housed in a NEMA 4X stainless steel enclosure.

### Transfer Switch VII.

- A. A manual transfer switch of adequate size to provide power via incoming electrical service or emergency generator power shall be provided.
- The transfer switch shall be built in the same enclosure as the main control center.
- C. A receptacle shall be provided to fit the Fall Creek Regional Waste District generator. Contact Tim Mccurdy at the Waste District for correct size.

### VIII. Control Center:

- A. The control center shall be built in a NEMA 4X stainless steel enclosure and shall be suitable for the specified horsepower and voltage for the pumping equipment. The outer door of the panel shall be hinged dead front with provisions for locking with a padlock. Inside shall be a separate hinged panel to protect all electrical components.
- B. The control center shall include a micro-processor base pump controller manufactured by USEMCO model 11928-5 (Without Exceptions) to control the pumps and to maintain the level in the wet well. The controller shall also receive a signal from the back-up floats and automatically switch to back-up if the 4-20ma signal is lost. Also shall include all necessary components for above controller to operate.
- C. A circuit breaker and magnetic starter (NEMA Rated) with three (3) leg overload protection (2 leg overload for single phase applications ) and manual reset shall be provided for each pump. Starters shall have auxiliary contacts, on three phase applications, to operate both pumps on over-ride condition. A separate circuit breaker shall be supplied for power to the control circuit. The control center shall include a control voltage transformer to reduce supply to 115 volt, single (1) phase. An alternating relay shall be provided to alternate pumps on each successive cycle of operation. A green light and H-O-A switch shall be provided for each pump. A terminal strip shall be provided to make field connections of pump power leads, float switches, seal sensor leads, and remote monitor panel interconnections.
- D. A time delay relay shall be provided to delay start of second pump should power outage occur.
- E. The control center shall incorporate connections for heat sensors which are installed in the pumps. The connection shall disconnect the starter upon high temperature signal, and will automatically reconnect when condition has been corrected.
- F. The control center shall incorporate connections for seal failure sensors which are installed in the pumps. The panel will have a seal failure alarm light for each pump. This alarm indicates failure of the lower mechanical seal in the pump. This will be a alarm light only and will not shut down the pump.
- G. The control center shall include an hour meter for each pump to register the elapsed operating time of each pump.

- side of the enclosure.
- in the control center.
- J. The control center shall include lightning protection.
- the lead pump.

# Μ. interconnection capability

- above.
- Relay contact to signal tripping of the overload of any
- of the pumps.
- 4. Relay contact to transmit signal of seal failure trip of any of the pumps
- Current transformer to provide amperage reading to signal Pump #1 run.
- Pump #2 run.

N. A minimum four (4) inch PVC schedule 40 wall conduit shall be provided from the wet well basin to the control center which will allow the pump power cables, sensor cables and float switch cables to be pulled through without difficulty and allow the use of one (1) piece cables from the pumps and float switches to the control center. The conduit shall be sealed at the control center to avoid entrance of sewer gases into the control panel.

- Ο. between the access drive and the wet well.
- and in stock by local sources.
- criteria.

# Level Controls

A inches outside diameter.

# Backup Mercury Float Switches:

Sealed float type mercury switches shall be supplied to control sump level and alarm signal. The mercury tube switches shall be sealed in a solid polyurethane float for corrosion and shock resistance. The support wire shall have a heavy Neoprene jacket and a weight shall be attached to the cord above the float to hold the float in place in the sump. The floats shall also be capable of supporting themselves from a stainless steel float bracket.

# XI. Backup System Operation:

On sump level rise, the
energized, then the up
start the lead pump. V
shall lower to lowest s
relay in the 'Control Ce
that the lag pump will s continues to rise when le
continues to rise when le
shall energize and start
shall operate together u
the level continues to ris
level switch shall energize
should fail for any reason
override switch. All leve
setting from the surface.

# Special Construction Control for Prairie Hollow

### RADIO TELEMETRY Integrity Engineering

H. The control center shall have a high water alarm built-in the main enclosure. The high water alarm shall consist of a flashing alarm light with red Lexan plastic cover or red glass globe with metal guard mounted on top of the enclosure such that it is visible from all directions. An alarm horn shall be mounted on the side of the enclosure. A push to test horn and light button as well as a push to silence horn button shall be provided and mounted on the

The control center shall include a condensate heater to protect against condensation inside the enclosure. The heater shall be placed so as not to damage any other component or wiring

K. The control center shall incorporate an alternator selector switch to allow selection of automatic alternation or manual selection of

The control center shall include a GFI convenience outlet with a 20 AMP breaker and suitable transformer or power supply to provide 110 single (1) phase power to the convenience

The control center shall be suitable for connection to a remote monitor package as described in the section titled "Remote Monitor Package". The main control must include the following

1. Circuit breaker to power remote monitor panel as described

Relay contact to signal high water alarm.

Current transformer to provide amperage reading to signal

The control center and associated components shall be mounted on a non-maintenance type pedestal or mounting stand constructed of aluminum. The control center shall be located so as to provide safe access to the panel while wet well hatch doors are opened, and shall be positioned so as not to be

All components of the control center shall be American made and available from local sources. In particular, items such as circuit breakers, overload protection, relays, etc. shall be available

Q. In order to maintain unit responsibility and warranty on the pumping equipment and control center, the control center must be accepted in writing by the pump manufacturer, as suitable for operation with the pumping equipment.

R. The control panel shall bear a UL label and meet UL508-698A

The liquid level of the wet well shall be sensed by a submersible level transducer model 6100 as manufactured by Sigma. The transducer shall be a 2-wire type to operate from a supply voltage of 15 to 45 VDC and produce a 4-20 mA instrumentation signal in direct proportion to the measured level excursion over a factory-calibrated range which will be indicated by readout on the front panel. It shall be of the head-pressure sensing type, suitable for continuous submerged, operation and shall be installed in accordance with the manufacturer's instructions. The bottom diaphragm face of the sensor will be installed where shown on the plans. The diaphragm, face shall be a minimum of 2.5

A. On sump level rise, the lower mercury switch shall first be upper level switch shall next energize and With the lead pump operating, sump level switch and turn off the pump. The alternating Center' shall index on stopping of the pump so start on the next operation. If sump level ead pump is operating, the override switch t the lag pump. Both lead and lag pumps until low level switch turns off both pumps. If ise when both pumps are operating, alarm ize and signal the alarm. If one pump on, the second pump shall operate on the el switches shall be adjustable for level

EXISTING FENCE NOTE: TOP OF CASTING SHALL EXTEND 0.20 FEET MINIMUM ABOVE FINISHED GRADE. -4"¢ PVC SCH. 80 RETURN BEND VENT (4) 3/8" X 3" STAINLESS STEEL ANCHOR BOLTS-/2" SHUTOFF VALVE-TO VENT. SEE PLAN PIPE THROUGH BARREL SECTION.~ QUICK DISCONNECT COUPLING -- 16" Ø x 30" CONCRETE BACK FLUSHING HOSE -AIR/VACUUM RELEASE -

#10 TRACER WIRE TO BE RUN INTO MANHOLE AND TIED TO TOP STEP

