





NAMEPLATE LEGEND

- | | |
|---------------------|----------------------|
| 1. EMERGENCY | 10. LOAD CENTER MAIN |
| 2. NORMAL | 11. CONTROL |
| 3. PUMP 1 | 12. CONVENIENCE |
| 4. PUMP 2 | 13. TELEMETRY |
| 5. PUMP 1 RTM | 14. FLOWMETER |
| 6. PUMP 2 RTM | 15. SITE LIGHT |
| 7. HOA RUN | 16. SPARE |
| 8. 1-2 AUTO 2-1 | 17. ALARM TEST |
| 9. NORMAL TEST FAIL | 18. ALARM SILENCE |

REV. NO.	REVISION	BY	DATE	DESIGNED BY:	DATE	BBC PUMP AND EQUIPMENT COMPANY, Inc. 777 N. TIBBS AVENUE P.O. BOX 22098 Indianapolis, Indiana 46222 317/636-1111
1	OUT TO SHOP	DS	7/13	MO	5/10	
2	AS BUILT	DS	9/5	DS	06	DESCRIPTION NORTHFIELD H.S.
		NB	06	CHECKED BY:	DATE	
				SCALE		DWG. NO. PNL 17591 BBC NO. 1606-66107

USEMCO, Inc.
Bill of Material
17591/1

8/21/200 7:42 AM
Page 1

17591/1
Northfield High School/BBC# 1606-66107

Detail	Quantity
----322265 HORN 120VAC EDWARDS #870P-N5	1.00
----322276.2 LIGHT ALARM AC-DC #BL5R-120VAC	1.00
----361100 INSULATOR NATURAL HARD FIBER .030" THICK ELECTRICAL GRADE 12" X 12" SHEET	0.25
----365294 LATCH SPRING W/KNURLED KNOB #57-10-201-10	2.00
----420415 RED RESET TELE LA9 BAORW	0.00
----420416.66 RESET OPERATOR TELE XB4 BA961 1.18 - 5.12" ACTUATION DISTANCE .55" TRAVEL BLUE	2.00
----421258.44 CONTACTOR TELE LC1 D32 G7	2.00
----421400 BREAKER PLUG-IN SQD QO110	1.00
----421406 BREAKER PLUG-IN SQD QO120	7.00
----421407 BREAKER PLUG-IN SQD QO220	0.00
----421494.07 BAR GROUND KIT SQD PK7GTA	1.00
----421494.21 RETAINING KIT SQD PK2MB	1.00
----421496 BREAKER INT ASSY QON8-16L100	1.00
----421529 BREAKER DOOR MOUNT SQD QOU-360	2.00
----421837.2 BREAKER 3 PL MLD CA FHL 36100	2.00
----422305 RELAY PROBE DIV. SPM-120-AAA-100K	2.00
----422339.10 RELAY 10A IDEC RH2B-U-AC120V	3.00
----422339.12 RELAY 10A IDEC RH2B-U-AC24V	2.00
----422339.22 RELAY 10A IDEC RH3B-U-AC24V	1.00
----422345 RELAY ALT 10A DIV. #ARA-120-ABA	1.00
----422348 RELAY PH MNTR DIV. #SLA-230-ASA	1.00
----423385.1 ARRESTOR LIGHTNING 4W 480V RED JACKET #104-018-5	1.00
----423419 BLOCK TERMINAL ENTRELEC-GRAY ENTRELEC PART #115 116.07	22.00
----423419.2 BLOCK TERMINAL ENTRELEC-YELLOW ENTRELEC PART #105 116.16	16.00
----423419.40 END STOP ENTRELEC-GRAY BAM2 ENTRELEC PART #206 351.16	2.00
----423419.5 END SECTION FEM6 COVER ENTRELEC ENTRELEC PART #118 368.16	1.00
----423419.7 JUMPER 10 POLE ENTRELEC ENTRELEC PART #168 973.07	1.00
----423441.04 BLOCK 1PL LINE #2/0 LOAD #4 2 LINE 6 LOAD MARATHON #1431555	1.00
----423480.2 SOCKET RD 8 PIN IDEC SR2P-06	3.00
----423481.2 SOCKET RD 11 PIN IDEC SR3P-06	2.00
----423484 SOCKET MIDGET 2P IDEC SH2B-05	5.00
----423485 SOCKET MIDGET 3P IDEC SH3B-05	1.00
----423565.44 OVERLOAD TELE LRD 32 23 TO 32 AMPS	2.00
----423566.44 OVERLOAD TELE LRD 3353 23 TO 32 AMPS	0.00
----424164 INTERLOCK CIRCUIT BREAKER-FAL	1.00
----425012.00 TIMER 120VAC DIV. TBC-120-ABA ON DELAY - 1.0 to 1023 SECONDS	1.00

USEMCO, Inc.
Bill of Material
17591/1

8/21/200 7:42 AM
Page 2

17591/1
Northfield High School/BBC# 1606-66107

Detail	Quantity
----425079 FLASHER 120VAC SSAC #FS127	1.00
----425204 RTM REDINGTON 120VAC #711-0165	2.00
----425360.3 TRNSFMR 50VA SQD 9070 T50D13	1.00
----425379.5 TRNSFMR 2KVA SQD 9070 T2000 D1 240 x 480 VOLT PRIMARY 120 VOLT SECONDARY	1.00
----426200 FUSE 600V FAST-ACTING 1 AMP 100,000 A.I.R. 1-1/2" LONG x 13/32" DIAMETER (BUSSMANN KTK-1) (LITTELFUSE KLK-1) (FERRAZ-SHAWMUT ATM-1)	3.00
----426211.0020 FUSE 600V TIME-DELAY 2 AMP CLASS CC 200,000 A.I.R. 1-1/2" LONG x 13/32" DIAMETER (BUSSMANN FNQ-R-2) (LITTELFUSE KLDR-2) (FERRAZ-SHAWMUT ATQR2)	1.00
----426211.0030 FUSE 600V TIME-DELAY 3 AMP CLASS CC 200,000 A.I.R. 1-1/2" LONG x 13/32" DIAMETER (BUSSMANN FNQ-R-3) (LITTELFUSE KLDR-3) (FERRAZ-SHAWMUT ATQR-3)	1.00
----426211.0100 FUSE 600V TIME-DELAY 10 AMP CLASS CC 200,000 A.I.R. 1-1/2" LONG x 13/32" DIAMETER (BUSSMANN FNQ-R-10) (LITTELFUSE KLDR-10)	2.00
----426520 BLOCK FUSE MARATHON 6M30A2SQ	2.00
----426520.02 BLOCK FUSE MARATHON 6M30A3SQ	1.00
----426525 BLOCK FUSE LITTELFUSE 354812GY	1.00
----428905.1 WIRE DUCT BASE 1.5" x 3"	7.00
----428908.1 WIRE DUCT COVER 1.5"	7.00
----429094.04 DECAL USEMCO 2"x3" MADE IN USA	1.00
----429105 DECAL: USEMCO LIMITED WARRANTY	1.00
----429118.40 WARNING SIGN BRADY #94913 WARNING ARC FLASH HAZARD APPROPRIATE PPE REQUIRED FAILURE TO COMPLY CAN RESULT IN DEATH OR INJURY REFER TO NFPA 70E	1.00
----445042 FUSE SLO BLO 3A 250V LITTELFUSE #313003 3AG BUSSMANN #MDL3	1.00
----460600 NIPPLE CHASE T&B 842 1/2"	1.00
----461025 BSHNG KNOCKOUT T&B #3213 1 1/4"	2.00
----462006 BOX C/AL 2x4 RED DOT IH3-1-LM	1.00
----462340.20 RECEIPT CROUSE-HINDS AR1041-S22 100 AMP 4 WIRE 4 POLE STYLE 1 WITH REVERSED CONTACTS	1.00
----462352.02 ADPT ANGLE 60/100A CR-HINDS AJA6	1.00
----462357.1 RECEIPT GFCI 20A 125V COOPER GF20V	1.00
----462854 ENCL N4X SCHAEFERS #SPN4SS-483612-WP SUB-PANEL	1.00

USEMCO, Inc.
Bill of Material
17591/1

8/21/200 7:42 AM
Page 3

17591/1
Northfield High School/BBC# 1606-66107

Detail	Quantity
----463442.3 TEMP SWITCH HOF A-TEMNC	1.00
----469004 LUG ALUM SOLDERLESS MAX. #2	4.00
ILSCO TA-2, BLACKBURN ADR-2, BRUNDY KA2U OR EQUAL	
----469005.0004 LUG POWER KIT SQD #PDC3FA2	2.00
----469070 HEATER PANEL 120V CHRO SCB-100	1.00
----469071 LAMPHOLDER PORCELAIN KEYLESS	1.00
ANGELLO #22273	
----470401 SWITCH TOG 3 POS MCGILL #91-0003	2.00
20 AMP ON OFF ON	
----470406 SWITCH TOG 3 POS 2GE64-73	1.00
----470500.1 SWITCH PB SQD 9001 SKR-1U	2.00
NEMA 4X CORROSION RESISTANT	
----470561 SWITCH PB NO CARLINGSWITCH #172	2.00
OR SELECTA SWITCH #SS228BG	
----472081 BLOCK CONTACT SQD 9001 KA2	2.00
----480110.10 LIGHT IND #930-505X-710RN-120	2.00
SCREW TYPE LUG LITTELFUSE	
----480111.10 LIGHT IND #930-505X-710GN-120	4.00
SCREW TYPE LUG LITTELFUSE	
----500549.486AL FLANGE, INNERDOOR 43"x 3.5"	1.00
----500567.AL INNERDOOR 48x36x08 N4&12 12"DP	1.00
----500583.12AL STANDOFF QOU7 FOR 8" DEPTH	1.00
----500584.20AL STANDOFF FAL INTERLOCK - 8" DEPTH	1.00
----500586.01AL STANDOFF DIST. FOR 8" DEPTH	1.00
----500587.01AL STANDOFF "INDY" FOR 8" DEPTH	1.00
-----421494.08 BAR GROUND KIT SQD PKOGTA2	1.00
-----421838 BREAKER 3 PL MLD CA FAL 36100	1.00
-----421888 ENCL CKT BREAKER SQD #FA100DS	1.00
-----421890 NEUTRAL ASSEMBLY SQD #SN100FA	1.00