



GROUND ELEV. = 840.0 ±  
 MAX. STATIC PRESS. = 138.5 PSI ±  
 REDUCED PRESS. 68.5 PSI ±

WEST COUNTY LINE ROAD

GROUND ELEV. = 760.0 ±  
 MAX. STATIC PRESS. = 173.2 PSI ±  
 REDUCED PRESS. 103.2 PSI ±



Robert E. Curry

REVISIONS

DRAWN BY	JC
DATE	10/1/91
CERTIFIED BY	REC
DATE	10/1/91

ROBERT E. CURRY & ASSOCIATES, INC.  
 CONSULTING ENGINEERS

ELROD WATER COMPANY INC.  
 DIVISION "D" DISTRIBUTION SYSTEM EXTENSIONS

4" PVC WATER MAIN  
 EXTENSION ALONG  
 WEST COUNTY LINE ROAD

JOB NO.	SHT. 26
SCALE 1" = 50'	OF 43