



PLAN VIEW - STA. 295+00 TO STA. 308+00 LINE "W-2"

NOTES:

1. THE UTILITIES AND THEIR LOCATION SHOWN ON PLANS ARE APPROXIMATE. CONTRACTOR SHALL VERIFY ALL UTILITIES IN THE FIELD AND NOTIFY ALL UTILITY

48" MINIMUM COVER REQUIRED OVER TOP OF WATER LINE UNLESS OTHERWISE NOTED.

COMPANIES PRIOR TO INSTALLATION OF THE WATER LINE. ALL PIPING SHALL BE CLASS 200 UNLESS OTHERWISE NOTED.

by Daniel R. Cutshaw, Indiana Professional Engineer, No. 11200431, or April 19, 2013, shall not be used in lieu of a certified document.

This document, originally issued, sealed, and signed

APRIL 2013 1"=50'

SCALE: 1" = 50'

THIS RECORD DOCUMENT HAS BEEN PREPARED BASED ON INFORMATION PROVIDED BY THE CONSTRUCTION CONTRACTOR. GRW ENGINEERS, INC. HAS ATTEMPTED TO VERIFY THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION BUT SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS

CONSTRUCTION COMPANY: LITTLE CREEK CONSTRUCTION, INC

749