

Oliver Springs

City/Utility: _____



RYE
ENGINEERING PLC

LEAK REPORT

Date: 3-19-20

Crew Chief:

☒
☐

Sheppard

Spears

Simmons

Moody

Leak #:

27

Street Address:

218 E Spring St.

Type of Leak:	Size:	Material:
Meter <input type="checkbox"/>	5/8" <input type="checkbox"/>	Poly <input checked="" type="checkbox"/>
Meter Yoke <input type="checkbox"/>	3/4" <input checked="" type="checkbox"/>	Copper <input type="checkbox"/>
Service Line <input checked="" type="checkbox"/>	1" <input type="checkbox"/>	Galvanized <input type="checkbox"/>
Valve <input type="checkbox"/>	2" <input type="checkbox"/>	PVC <input type="checkbox"/>
Fire Hydrant <input type="checkbox"/>	3" <input type="checkbox"/>	A/C <input type="checkbox"/>
Main Line <input type="checkbox"/>	4" <input type="checkbox"/>	Cast Iron <input type="checkbox"/>
Other: _____	6" <input type="checkbox"/>	Ductile Iron <input type="checkbox"/>
	8" <input type="checkbox"/>	Other: _____
	10" <input type="checkbox"/>	
	12" <input type="checkbox"/>	
	16" <input type="checkbox"/>	
	18" <input type="checkbox"/>	
	20" <input type="checkbox"/>	
	24" <input type="checkbox"/>	
	30" <input type="checkbox"/>	
	36" <input type="checkbox"/>	
	Other <input type="checkbox"/>	

Rating (1-5):

3

☐

Blue Dot on Box

☒

Blue X on Leak Location

Arrow pointing to Leak location.

Notes: _____

This is calculated at 60 PSI:

Leak Location Sketch:

Rating	Pipe Leak Size	Gallons Lost/Day	
1	•	400	
2	•	3,000	
3	•	8,000	
4	•	15,000	
5	Severe Leak - Repair as soon as possible (20,000+ per day)		