

City/Utility: Oliver S Adams



RYE
ENGINEERING PLC

LEAK REPORT

Date: 2-17-28

Crew Chief: ☒ Sheppard

Simmons ☐

Leak #: 9

☐ Spears

Moody ☐

Street Address: 2116 Forest

Type of Leak:	Size:	Material:
Meter <input type="checkbox"/>	5/8" <input type="checkbox"/>	Poly <input type="checkbox"/>
Meter Yoke <input type="checkbox"/>	3/4" <input type="checkbox"/>	Copper <input type="checkbox"/>
Service Line <input type="checkbox"/>	1" <input type="checkbox"/>	Galvanized <input type="checkbox"/>
Valve <input type="checkbox"/>	2" <input type="checkbox"/>	PVC <input type="checkbox"/>
Fire Hydrant <input type="checkbox"/>	3" <input type="checkbox"/>	A/C <input type="checkbox"/>
Main Line <input type="checkbox"/>	4" <input type="checkbox"/>	Cast Iron <input type="checkbox"/>
Other: _____	6" <input type="checkbox"/>	Ductile Iron <input type="checkbox"/>
	8" <input type="checkbox"/>	Other: _____
	10" <input type="checkbox"/>	
	12" <input type="checkbox"/>	
	16" <input type="checkbox"/>	
	18" <input type="checkbox"/>	
	20" <input type="checkbox"/>	
	24" <input type="checkbox"/>	
	30" <input type="checkbox"/>	
	36" <input type="checkbox"/>	
	Other <input type="checkbox"/>	

Rating (1-5): 3

☐ Blue Dot on Box

☒ Blue X on Leak Location

Notes: Arrow pointing to location

This is calculated at 60 PSI:

Leak Location Sketch:

Rating	Pipe Leak Size	Gallons Lost/Day
1	•	400
2	•	3,000
3	•	8,000
4	•	15,000
5	Severe Leak - Repair as soon as possible (20,000+ per day)	