



Defect Listing

Pipe Segment Refere...	City	Street	Material	Location C...	Sewer Use
D6-6_D6-5	Oliver Springs	Dale st	Concrete Pipe (non-...	Light High...	Sanitary
Upstream MH	Total Length	Year Laid	Shape	Location Details	
D6-6	194.1		Circular		
DS Manhole	Length surveyed	Year Renewed	Height	Width	Pipe Joint...
D6-5	194.1		8	8	4


SPR	N/A	MPR	2	PO Number	Customer
SPRI	N/A	MPRI	2	4397-03	GRW
QSR	N/A	QMR	2100	Work Order	Purpose
				4397-02	Pre-Rehabilitation Survey
OPR	Surveyed By	Direction	Date	Media label	
2	Barry Rogers	Downstream	20150706		
OPRI	Certificate Number	Pre-Cleaning	Time	Weather	
2	U-1012-16405	Jetting	09:40	Dry	
Date Cleaned			End Time	Additional Info	
20150706			09:53		

Distance	Condition	Cont. Dfct.	Values			Joint	Clock Position		Grade
			1st	2nd	%		At/From	To	
0.0 ft.	Access Point Manhole				0	<input type="checkbox"/>			
Remarks: D6-6									
0.0 ft.	Water Level				5	<input type="checkbox"/>			
10.2 ft.	Water Level Sag				10	<input type="checkbox"/>			2
12.5 ft.	Tap Factory Made		6		0	<input type="checkbox"/>	3		
68.5 ft.	Tap Factory Made		6		0	<input type="checkbox"/>	3		
107.9 ft.	Tap Factory Made		6		0	<input type="checkbox"/>	9		
190.5 ft.	Tap Factory Made		6		0	<input type="checkbox"/>	9		
191.1 ft.	Water Level				5	<input type="checkbox"/>			
194.1 ft.	Access Point Manhole				0	<input type="checkbox"/>			
Remarks: D6-5									




Image Report 4/Page


Pipe Segment Refere...	City	Street	Material	Location C...	Sewer Use
D6-6_D6-5	Oliver Springs	Dale st	Concrete Pipe (non-...	Light High...	Sanitary
Upstream MH	Total Length	Year Laid	Shape	Location Details	
D6-6	194.1		Circular		
DS Manhole	Length surveyed	Year Renewed	Height	Width	Pipe Joint...
D6-5	194.1		8	8	4




Distance: 0.0 ft. Grade: 0
Condition: Access Point Manhole
Remarks: D6-6



Distance: 0.0 ft. Grade: 0
Condition: Water Level
Remarks: N/A



Distance: 10.2 ft. Grade: 2
Condition: Water Level Sag
Remarks: N/A




Distance: 12.5 ft. Grade: 0
Condition: Tap Factory Made
Remarks: N/A



Image Report 4/Page

Pipe Segment Refere...	City	Street	Material	Location C...	Sewer Use
D6-6_D6-5	Oliver Springs	Dale st	Concrete Pipe (non-...	Light High...	Sanitary
Upstream MH	Total Length	Year Laid	Shape	Location Details	
D6-6	194.1		Circular		
DS Manhole	Length surveyed	Year Renewed	Height	Width	Pipe Joint...
D6-5	194.1		8	8	4



Distance: 68.5 ft. Grade: 0
Condition: Tap Factory Made
Remarks: N/A



Distance: 107.9 ft. Grade: 0
Condition: Tap Factory Made
Remarks: N/A



Distance: 190.5 ft. Grade: 0
Condition: Tap Factory Made
Remarks: N/A



Distance: 191.1 ft. Grade: 0
Condition: Water Level
Remarks: N/A



Image Report 4/Page

Pipe Segment Refere...	City	Street	Material	Location C...	Sewer Use
D6-6_D6-5	Oliver Springs	Dale st	Concrete Pipe (non-...	Light High...	Sanitary
Upstream MH	Total Length	Year Laid	Shape	Location Details	
D6-6	194.1		Circular		
DS Manhole	Length surveyed	Year Renewed	Height	Width	Pipe Joint...
D6-5	194.1		8	8	4



Distance: 194.1 ft. Grade: 0
Condition: Access Point Manhole
Remarks: D6-5



Pipe Segment Refere...	City	Street	Material		Location C...	Sewer Use
D6-6_D6-5	Oliver Springs	Dale st	Concrete Pipe (non-...		Light High...	Sanitary
Upstream MH	Total Length	Year Laid	Shape		Location Details	
D6-6	194.1		Circular			
DS Manhole	Length surveyed	Year Renewed	Height	Width	Pipe Joint...	
D6-5	194.1		8	8	4	
SPR	N/A	MPR	PO Number		Customer	
SPRI	N/A	MPRI	4397-03		GRW	
QSR	N/A	QMR	Work Order		Purpose	
			4397-02		Pre-Rehabilitation Survey	
OPR	Surveyed By	Direction	Date		Media label	
2	Barry_Rogers	Downstream	20150706			
OPRI	Certificate Number	Pre-Cleaning	Time		Weather	
2	U-1012-16405	Jetting	09:40		Dry	
Date Cleaned			End Time		Additional Info	
20150706			09:53			

Page #: 5